



Multibore Capillary UF Module

HYDRAcap®40-LD-A

NaOH, HCI, H2SO4, or Citric Acid

Performance* Filtrate Flow: $5 - 12.3 \text{ gpm } (1.1 - 2.8 \text{ m}^3/\text{h})$

Filtrate Turbidity: ≤ 0.07 NTU
Virus removal ≥ 4 log
Bacteria removal ≥ 4 log

Type Configuration: Capillary Ultrafiltration Module

Membrane Polymer: Hydrophilic Polyethersulfone

Nominal Membrane Area: 208 ft² (19.3 m²)
Fiber Dimensions: Bore Diameter 0.055" (

Fiber Dimensions:

Bore Diameter 0.055" (1.4 mm)
Outer Diameter 0.232" (5.9 mm)

Pore size: 0.02 micron

Application Data[†] Typical Filtrate Flux Range: 35 – 85 gfd (59 – 145 l/m²/h)

Maximum Applied Feed Pressure: 73 psig (5 bar)[‡]
Maximum Transmembrane Pressure 20 psig (1.4 bar)
Maximum Backwash Transmembrane Pressure: 20 psig (1.4 bar)
Instantaneous Chlorine Tolerance: 100 ppm[§]

Instantaneous Hydrogen Peroxide Tolerance: 200 ppm§

Maximum Chlorine Exposure: 200,000 ppm-hrs Maximum Instantaneous Feed Turbidity: 200 NTU

Maximum Operating Temperature: 104 °F (40 °C) pH Operating Range: 4.0 - 10.0 Cleaning pH Range: 1.5 – 13.0

Operating Mode: Inside to Outside Filtration
Dead end or Crossflow

Typical Process Conditions


Cleaning Chemicals:

Backwash Flux: 100 – 150 gfd (170 – 255 l/m²/h)

Backwash Duration: 30 – 60 seconds
Backwash Frequency: 20 – 60 minutes
Chemical Enhanced Backwash Frequency: 0 – 4 times per day

Chemical Enhanced Backwash Duration: 1 – 30 minutes

Disinfection Chemicals: NaOCI, H₂O₂, CIO₂ or NH₂CI



A, inches (mm)	B, inches (mm)	C, inches (mm)	Pipe connections	Weight, Ibs. (kg) ave.
43 (1092)	46 1/8 (1172)	47 1/4 (1200)	2" Victaulic	63 (28)

Certifications:

NSF61. Acceptable for drinking water use under LT2ESWTR.

[†] The limitations shown here are for general use. The values may be more conservative for specific projects to ensure the best performance and longest life of the membrane.



§ For 15 minutes or less.

Notice: Weight stated is shipping weight including 1L of a 10% Glycerin/18% Polypropylene glycol/72% water preservative.

Hydranautics believes the information and data contained herein to be accurate and useful. The information and data are offered in good faith, but without guarantee, as conditions and methods of use of our products are beyond our control. Hydranautics assumes no liability for results obtained or damages incurred through the application of the presented information and data. It is the user's responsibility to determine the appropriateness of Hydranautics' products for the user's specific end uses.

3/20/2017



Typical module performance for most feedwaters.